

Indiana State Department of Health
Consumer Services and Health Care Regulation Commission
Division of Acute and Continuing Care

**COVID-19 NATIONAL/STATE EMERGENCY HOSPITAL BLANKET WAIVER:
CONVERSION OF STANDARD PATIENT ROOMS TO NEGATIVE PRESSURE
ISOLATION ROOMS**

ISDH CSHCR: Program Advisory Letter

Number: **AC-2020-01-HOSP**

Effective Date: RETROACTIVE TO March 6, 2020

Created: March 21, 2020

Cancels: None

Reviewed: n/a

Revised: n/a

BLANKET WAIVER SUMMARY

- ***Retroactive to March 6, 2020***
- ***A blanket waiver from state rules and FGI Guidelines regarding the requirements for isolation rooms. Facilities and design firms will not be required to submit waiver requests or plan designs for converting non-isolation rooms to isolation rooms during the declared National and State COVID-19 Emergency. The ISDH hereby issues a blanket waiver applicable to all hospitals subject to the requirements of this notice.***

Background:

Due to the anticipated magnitude of patients presenting to hospitals due to concerns related to the COVID-19 viral infection, hospitals may have a need to add additional negative pressure isolation rooms in order to protect patients and staff within the facility as patients with suspected or confirmed cases of COVID-19 undergo medical management and treatment.

Policy:

1. Isolation (negative air pressure) room requirements per FGI, 2018 Edition are hereby suspended.
2. Facilities will not be required to submit waiver requests or plan review documents for the modification of currently approved inpatient rooms.

**Indiana State Department of Health
Consumer Services and Health Care Regulation Commission
Division of Acute and Continuing Care**

3. A negative air pressure room shall meet or exceed -2.5 (negative 2.5) pascals or the -0.01 (negative 0.01) water inches.
4. All air from a room converted to a negative pressure room shall be:
 - a. Exhausted externally from the building or;
 - b. All exhaust shall be routed through a HEPA (99.7% efficient) filter and only returned back to isolation rooms.
5. Externally exhausted air shall be exhausted 25 (twenty-five) feet or greater from any other air intake.
6. Policies and procedures are required for the disposal of human waste in any room converted to negative pressure that does not have an in-room toilet/bathroom.
7. Any room or area other than a toilet/bathroom servicing the negative pressure room shall be positive to the negative pressure room.
8. A visual pressure monitoring mechanism must be present which indicates the air pressure status of the room at all times in which a patient is present in the negative pressure room.
9. The facility shall implement some type of monitoring system/device/process to ensure the negative pressure room remains continuously negative during the patient's length of stay in the negative pressure room.
10. All surfaces within the negative pressure room shall be or made to be easily cleanable and able to be properly disinfected.
11. Prior to use, rooms converted under this emergency blanket waiver must have an ISDH onsite inspection. The facility shall request the inspection but shall do so only when the conversion is complete and the inspector can verify the room meets the requirement in paragraph 3 above using the mechanism referred to in paragraph 8 above.

NOTE: If rooms have been converted prior to the issuance of this blanket waiver, contact the ISDH to request an 'as converted' inspection of the room(s).

12. This emergency waiver is time limited to the duration of the COVID-19 public health emergency. If a facility wishes to make the negative pressure rooms permanent, the room(s) must be submitted for plan review and designed to the FGI 2018 Edition requirements for negative pressure rooms.


**Indiana State Department of Health
Consumer Services and Health Care Regulation Commission
Division of Acute and Continuing Care**

Questions:

Questions about this program advisory letter may be addressed to Todd Hite, Program Director, Health Care Engineering (317) 233-7166, email: thite@isdh.in.gov or Jennifer Hembree, Hospital Program Director, email: jhembree@isdh.in.gov

Kristina Box, MD, FACOG
State Health Commissioner

By:

A handwritten signature in blue ink, appearing to read 'M Foster', is written over a horizontal line.

Matthew Foster, Assistant Commissioner
Consumer Services & Health Care Regulation

Date: March 21, 2020